



BOARD OF HEALTH PUBLIC NOTICE

JUNE 12, 2017

5:30 P.M.

**BOULDER COUNTY PUBLIC HEALTH AUDITORIUM
3450 BROADWAY, BOULDER, COLORADO**

During its regularly scheduled meeting on the above date and time, the Boulder County Board of Health will conduct a public hearing to consider a variance for the onsite wastewater treatment system (OWTS) at 24409 Peak to Peak Highway, Nederland, Colorado (Applicant: Thomas Akins). The request is for authorization to locate a leach field 10 feet from the property dwelling rather than the required 20-foot setback.

Rationale for the variance request is available for review by submitting a request to healthows@bouldercounty.org or contacting the Boulder County Public Health Environmental Health Division, 3450 Broadway, Boulder, Colorado, at 303-441-1564 between the hours of 8:00 a.m. and 4:30 p.m., Monday-Friday.

If special assistance is needed to attend the Board of Health meeting, please call 303-441-1100 at least 72 hours prior to the meeting.