



Land Use

Courthouse Annex • 2045 13th Street • Boulder, Colorado 80302 • Tel: 303.441.3930 • Fax: 303.441.4856
Mailing Address: P.O. Box 471 • Boulder, Colorado 80306 • www.bouldercounty.org

**BOULDER COUNTY FIRE CODE REVIEW COMMITTEE
AGENDA
July 11, 2018
3:30 PM
Caribou Conference Room
2nd Floor Courthouse Annex**

Public Hearing

AFTERNOON SESSION 3:30 PM

1. Call to order by the Chair
2. Roll call of members present by the Secretary of the Board
3. Approval of the Minutes Summary
Minutes of the May 7, 2018 FCRC public hearing (Berthoud FPD)
4. Public Hearing

FCRC-18-0001: Berthoud Fire Protection District
 1. Presentation of the Berthoud Fire Protection District's adoption of, and amendments to, the 2018 International Fire Code
 2. Public testimony or comment by interested parties and members of the public
 3. Review and discussion by the Fire Code Review Committee
 4. Vote to recommend approval or rejection of the fire code adoption
5. Other Business
 - a. No future meeting dates scheduled
6. Adjournment



Land Use

Courthouse Annex • 2045 13th Street • Boulder, Colorado 80302 • Tel: 303.441.3930 • Fax: 303.441.4856
Mailing Address: P.O. Box 471 • Boulder, Colorado 80306 • www.bouldercounty.org

Boulder County Fire Code Review Committee

Minutes (DRAFT)

May 7, 2018

2:00 PM

Caribou Conference Room
2nd Floor Courthouse Annex

On May 7th, the Boulder County Fire Code Review Committee met to discuss the adoption and amendments of the 2018 International Fire Code by Berthoud Fire Protection District. The meeting convened at 2:01 pm.

Board Members Present: Bruce Honeyman, Michelle Kelly, Toby Myers, and Jeff Webb.

Board Members Not Present: Brett Haberstick

Staff Present: Ron Flax (Chief Building Official), Kathy Acosta (Permit Specialist Supervisor), and Liz Cross (County Attorney).

Interested Others: None

1. Call to Order

Jeff Webb called the meeting to order.

2. Minutes

Approval of Fire Code Review Committee minutes from November 8, 2017 (Boulder Rural FPD)

Motion: Toby Myers moved to approve the minutes

Second: Michelle Kelly

Vote: Motion approved

3. Public Hearing

FCRC-18-0001 – BERTHOUD FIRE PROTECTION DISTRICT REQUESTS TO ADOPT AND AMEND THE 2018 INTERNATIONAL FIRE CODE

Ron Flax went over the staff recommendation for the adopting resolution submitted by Berthoud FPD. The comments listed and discussed in regards to the proposed Fire Code included (1) the encouragement of adopting the latest edition of the International Fire Code, (2) Appendix E has a statement indicating it is only for informational purposes, (3) Appendix G was not mentioned, although in the 2012 Adoption Resolution, it is specifically excluded, so staff recommends clarification on that, and (4) Clarification on Temporary Membrane Structures and Tents.

The Fire Code Review Committee went over some questions and recommendations they had on the code, which included items such as adding the name of the jurisdiction in Section 101.1; changing the wording for permitting to “shall” instead of “may”; changing from Building Code Official to Fire Code Official in Section 105.6.47; adding a section to sky lanterns; adding code

provisions to Appendix I; include all fire lanes, rather than just “installed” fire lanes in in the Fire Lane Code; add “pasture land” to the Weeds, Tall Grass, Trash & Garbage Code.

Berthoud will take the suggested changes to their Board to review, approve, and then resubmit.

Motion: Bruce Honeyman moved to table pending review of requested changes by the Fire Code Review Committee.

Second: Toby Myers

Vote: Motion approved unanimously

5. Other Business

None.

6. Adjourned

Motion: Jeff Webb

Second: Michelle Kelly

Vote: Motion approved unanimously.

The meeting was adjourned at 3:09 pm.

The official record of this meeting is usually on mp3. Detailed information regarding the docket items, including maps and legal descriptions are available for public use at the Land Use Department, 13th and Spruce, Boulder, CO, 303-441-3930.



Land Use

Courthouse Annex • 2045 13th Street • Boulder, Colorado 80302 • Tel: 303.441.3930 • Fax: 303.441.4856
Mailing Address: P.O. Box 471 • Boulder, Colorado 80306 • www.bouldercounty.org

Building Safety & Inspection Services Team

**BOULDER COUNTY FIRE CODE REVIEW COMMITTEE
DOCKET #FCRC-18-0001
PUBLIC HEARING
BERTHOUD FIRE PROTECTION DISTRICT FIRE CODE
(2018 IFC)
Wednesday, July 11, 2018 – 3:30 P.M.
Boulder County Land Use Department
Caribou Conference Room, 2nd Floor, Courthouse Annex
2045 13th St., Boulder, CO 80302**

Staff: Ron Flax, Chief Building Official, Secretary to the Fire Code Review Committee

Overview and Update: This hearing is a continuation of Docket #FCRC-18-0001. During the previous hearing on May 7, 2018, the committee voted to table the docket to allow the applicant time to address several items of concern. Since that time, the applicant has submitted a revised copy of Resolution 2018-04-24A from the Berthoud Fire Protection District.

In addition to a number of editorial and formatting corrections, the following changes were made:

1. Page 1 Deleted **appendix E**
2. Page 3 Added Section 101.1 **“Name of the Jurisdiction”**
3. Page 4 Listed required operational permits and inserted **“shall”** instead of may, but **added a sentence that states I “may” at some point require permits listed in Sections 106.6.1 thru 105.6.50.**
4. 105.6.47 deleted building and **added fire code official.**
5. Note on Page 5, **Section 110 was unchanged.** The Fire Chief would like to keep this section as is to avoid conflict with the Sheriff(s) departments or other law enforcement agencies.
6. Page 7. **308.1.6.3 was added** in front of “Sky Lanterns”
7. Page 8. Made the Additional Code Provisions an **Appendix I.** with a line stating that these provisions are a requirement for ISO audits. That is why they are in there. Under BBQ grills added “Propane Grills”.
8. Page 10 Fire Lanes, deleted the word **“installed”.**
9. Page 11 INTENT Added **“Applicable State and Federal Law”**
10. Page 12 Transporter deleted the word legal and added **prohibited.**
11. Page 13 Added **“Pasture Land”**

Otherwise the revised document remains identical to the document that was reviewed and discussed during the May 7, 2018 hearing.

The following portions of the staff report remain unchanged from the report that was submitted for the May 7th, 2018 hearing (with the exception of the attachment referencing the revised document from the Berthoud FPD):

The Berthoud Fire Protection District (“FPD”) lies generally in the extreme northeastern area of unincorporated Boulder County north of the City of Longmont and also extends into Larimer and Weld counties. In Boulder County, it is bounded to the west by the Lyons Fire Protection District and to the south by the Hygiene and Mountain View FPDs.

The district’s board of directors has adopted the 2018 edition of the International Fire Code (IFC), including the following appendices: B, C, D, E, F, H, I, K & N.

With the exception of the additions of adopting Appendices K and N, this adoption resolution is largely similar to previous adoption resolutions.

Staff has the following comments on the proposed fire code adoption:

1. **2018 Edition.** Adopting the latest edition of the Fire Code is encouraged. In this instance, the Berthoud FPD is ahead of Boulder County as Boulder County has not yet adopted the 2018 version of the I-Codes. Boulder County does intend to pursue the adoption of the 2018 Codes and anticipates that this process will begin during 2019.
2. **Appendices.**
 - a. Appendix E of the 2018 IFC include the statement, “This appendix is for information purposes and is not intended for adoption.” With this in mind, it is staff’s recommendation that this appendix be removed from the list of adopted appendices.
 - b. Appendix G was not mentioned in the Berthoud FPD Resolution. In the resolution adopting the 2012 Fire Code, Appendix G was specifically excluded. Staff recommends clarifying that Appendix G is not being adopted by the Berthoud FPD (assuming that this is the intention of the district).
3. **Temporary Membrane Structures and Tents.**
 - a. The text of Section 105.6.47 reads: “*An operational permit and construction permit may be required and issued by the building or fire official to operate an air supported temporary membrane structure, a temporary special event structure or a tent having an area in excess of 400 square feet.*”
 - i. The use of the work “or” creates a situation where it is unclear as to when the applicant would need a permit from Boulder County Building Safety and Inspection Services, when they would need a permit from the Berthoud Fire Protection District, and when they would need both. It should be noted, that this same conflict existed in the previously adoption of the 2012 Codes (but due to the low number of relevant projects it has not been problematic). Staff is not recommending any specific solution to this situation, but rather wanting to make sure that there was an awareness of this issue (with

the intention that any potential conflicts are addressed with appropriate policies enacted by the jurisdictions involved).

- ii. It should also be noted that the size threshold in this section has been reduced to 400 sqft (where previously it was 750 sqft).

STAFF RECOMMENDATION: Staff recommends that the Fire Code Review Committee recommend to the Board of County Commissioners that the proposed Berthoud FPD Fire Code be ACCEPTED for administration by the district in those portions of unincorporated Boulder County that lie within the boundaries of the fire protection district, with the stipulations as noted in the staff recommendation.

Attachments: Berthoud FPD Fire Code Adopting Resolution 2018-04-24A
Map of Berthoud FDP Tax district.

**BOULDER COUNTY RESOLUTION 2018 -04-24A
BERTHOUD FIRE PROTECTION DISTRICT**

A RESOLUTION ADOPTING THE 2018 INTERNATIONAL FIRE CODE, CERTAIN FIRE CODE STANDARDS, APPENDICES AND CERTAIN MODIFICATIONS THERETO, PRESCRIBING REGULATIONS GOVERNING CONDITIONS HAZARDOUS TO LIFE AND PROPERTY FROM FIRE OR EXPLOSION, AND PROVIDING FOR THE ISSUANCE OF PERMITS FOR HAZARDOUS USES OR OPERATION.

WHEREAS, the Board of Directors of the Berthoud Fire Protection District (the "District") deems it necessary to adopt the following code for the purpose of establishing rules of conduct and standards for the protection of life, health, property, security and welfare of the inhabitants of the District; and

WHEREAS, the Board of Directors has considered the effect of fire code enforcement within the boundaries of the District and has determined that enforcement of the proposed codes would not cause undue hardships or suppression of economic growth within the District; and

WHEREAS, the Board of Directors has studied the necessity of realistic and reasonable levels of fire protection to be provided by a rural fire protection district which also includes area of high density municipal development, including industrial and commercial.

NOW, THEREFORE, BE IT RESOLVED THAT:

Adoption of the 2018 International Fire Code and Fire Service Standards

There is hereby adopted by the District for the purpose of prescribing regulations governing conditions hazardous to life and property from fire, hazardous materials, or explosion, that certain Codes and Standards known as the International Fire Code and Referenced Standards Chapter 80, including the following appendices: B, C, D, F, G, H, I, K & N (but specifically excluding Appendix A, E, J, L & M, and further including the National Fire Protection Association Standards listed in Chapter 80, Referenced Standards, published by the International Fire Code Council, being particularly the 2018 Editions thereof and the whole thereof, save and except such portions as are hereinafter deleted, modified, or amended by the Resolution of which said Codes and Standards are now filed in the offices of the District, and the same are hereby adopted and incorporated as fully as set out at length herein.

The date on which this Resolution shall take effect within the unincorporated counties within the District shall be the approval by the governing board of said counties and the date on which take effect within the unincorporated County of Boulder shall be the date of approval of the County Commissioners in and for the County of Boulder, State of Colorado.

ESTABLISHMENT AND DUTIES OF FIRE PREVENTION INSPECTORS

Organizational structure and duties of the Fire Prevention Bureau or Department, if any shall be organized by the District's bylaws.

DEFINITIONS

Wherever the word "District" is used, it shall mean the Berthoud Fire Protection District.

Wherever the word "Jurisdiction" is used in the adopted Code and Standards, it is meant to be inclusive of the boundaries of the District as they now or may hereafter exist.

Where the term "Chief" or "Chief of the Bureau of Fire Prevention" is used it shall mean the Chief of the District or the District Fire Marshal or designated member of the District.

Where the term "Bureau of Fire Prevention" is used, it shall be held to mean either the entire Department or those employees (paid or volunteers) designated by the Chief or Fire Marshal to carry out enforcement duties relating to the prevention of fires and the suppression of arson.

Where the term "Board" is used, it shall mean the Board of Directors of the District.

Where the term "Code" is used, it shall mean the International Fire Code as adopted.

Wherever the term "International Building Code" is used, it shall be held to mean the International Building Code as adopted, amended and incorporated into the Boulder County Building Codes for unincorporated portions of such counties or the International Building Code as adopted, amended and incorporated into the applicable municipality's Building Code within a municipality's territorial limit.

ESTABLISHED LIMITS IN WHICH STORAGE OF LIQUIFIED PETROLEUM GAS IS TO BE RESTRICTED

The limits referred to in Section 6101 of the 2018 International Fire Code, in which the storage of liquified petroleum gas is restricted, are hereby established as follows;

As addressed by any ordinance or zoning regulation adopted by Boulder County or municipalities, which are more restrictive than Section 6101. This section shall not be interpreted so as to conflict with provisions of § 34-64-101 et seq. and §34-64-101 et seq., CRS.

AMENDMENTS MADE IN AND TO THE INTERNATIONAL FIRE CODE

SECTION 101

SCOPE AND ADMINISTRATION

Section 101.1 Title. These regulations shall be known as the *Fire Code* of Berthoud Fire Protection District, hereinafter referred to as "this code".

SECTION 103

DEPARTMENT OF FIRE PREVENTION

Section 103.4 Liability shall be amended by the addition of the following sentence; "Nothing herein shall be construed as a waiver of any immunity provided by § 24-10-101, et seq., CRS or any other statutes, or by the common law.

Section 104 GENERAL AUTHORITY AND RESPONSIBILITY shall be amended with the insertion of the following;

Section 104.1.1 Inspection Fees and Charges

(a) Pursuant to §32-1-1002(1)(e)(II) CRS., the Board may fix from time to time and may increase and decrease fees and charges at its discretion, for inspections and review of plans and specifications which are:

(1) Requested or mandated for existing structures, buildings, and improvements;
and

(2) Necessitated in conjunction with county regulation, resolution or condition of Development; or

(3) Performed in conjunction with construction of new structures, buildings, and improvements.

(b) Said fees and charges may, at the discretion of the Board, include a charge for reimbursement to the District for any consultation fees, expenses or costs incurred by the District in the performance of the inspections or review of plans and specifications.

Section 104.9 Alternative materials, design, and methods of construction and equipment shall be amended with the insertion of the following;

(a) The Chief or his designee may determine the suitability of alternative materials,

Design, and method of construction and equipment to facilitate the review process. In the event of disagreement, the District's Board shall determine the suitability of alternative materials, methods of construction and equipment and provide reasonable interpretations of the provisions of this Code upon request of any interested party, including the Chief.

- (b) The Board, upon recommendation of the Chief or upon its own motion, may enter into written agreements for enforcement or compliance with the owner lessee, occupant or authorized agent thereof, of any property, building or structure, or any interested person directly affected by the application of this code. Said agreements may extend the time for compliance with this code, and may contain such terms and conditions that the Board deems appropriate to adequately protect life, health, property, security and welfare of the public.

Section 105.6 is repealed and reenacted to read:

105.6 Required Operational Permits.

The fire code official shall require and issue an operational permit(s) for the following:

1. Temporary Membrane Structures and Tents.
2. Fire Works Stands.

Operational permits *may* be required for the operations set forth in Sections 105.6.1 through 105.6.50 operations set forth in Sections 105.6.1 through 105.6.50 as he/she deems necessary.

Section 105.6.32 shall be amended with the insertion of the following:

Open Burning. Permits are required for all open burning and other fire management practices from the respective counties of Boulder, Larimer and Weld. The counties' Health Departments shall review all permit applications and either approve or deny them. Permits are forwarded to the Fire Chief or his designee for inspection of the site and final approval.

Exception: This shall not apply to Agricultural Burning

105.6.47 Temporary Membrane Structures and Tents. This section shall be amended in the first paragraph with the insertion of the following:

An operational permit and construction permit shall be required and issued by the fire code official to operate an air supported temporary membrane structure, a temporary special event structure or a tent having an area in excess of 400 square feet. In exception 2.1 and 2.2, 700 square feet is replaced with 1000 square feet.

105.7 Required Construction Permits shall be amended to read:

All construction permits will be issued by the building official. The District's Fire Prevention Bureau will be the approving authority for the following:

- a. 105.7.1 Automatic fire-extinguishing systems
- b. 105.7.7 Fire alarm and detection systems and related equipment
- c. 105.7.8 Fire Pumps and related equipment
- d. 105.7.21 Solar photovoltaic power systems
- d. 105.7.24 Standpipe systems

SECTION 109 BOARD OF APPEALS

Section 109.1, 109.2 and 109.3 are repealed and reenacted to read:

- a. The District Board shall serve as its own Board of Appeals. The Board may form a subcommittee consisting of three members of the Board to hear appeals brought before it of any and all orders issued by the Chief or his designee. The Board, or such subcommittee acting on behalf of the Board, shall determine the suitability of any suggested alternate materials and methods and type of construction and provide reasonable interpretations of the provisions of this Code upon request of any interested party, including the Chief.
- b. The Board upon recommendation of the Chief or upon motion, may enter into written agreements for enforcement or compliance with the owner, lessee, occupant or agent thereof, of any property, building or structure, or any interested person directly affected by the application of this Code. Said agreements may extend the time for compliance with this Code, and may contain such terms and conditions that the Board deems appropriate to adequately protect the life, health, property, security, and welfare of the public.

SECTION 110 VIOLATIONS

Section 110 is repealed and reenacted to read:

- 1. The Chief or his designee shall enforce this code and shall inspect or cause to be inspected all buildings, structures, property, premises, and public places, except the interior of any private dwelling, in accordance with the procedures set forth in §32-1-1002(3), C.R.S. All inspections shall be recorded.

2. A "Notice" of Violation Hazard" may be issued by the Chief or his designee concerning violations of hazards which are not corrected on-site during an inspection. Said notice shall be signed by the inspector and contain, as a minimum, the following information:

1. Date of Inspection;
2. Name/Address of premise inspected;
3. Nature of violation or hazard;
4. Time limit for correction;
5. Right to appeal, if any to the Board;
6. Right to appeal to the District Court and time limit;
7. Penalties for violation or order;
8. Signature of the Chief or his designee;
9. Acknowledgement of receipt signed by owner, lessee, agent, or other responsible person.

3. An "Order for Immediate Correction of Hazard" may be issued by the Chief:

a. For Failure to correct a violation hazard within the time specified in previously issued Notice of Violation Hazard; or

b. For violating the code or state statute and said violation renders the building, structure or premises especially liable to fire or is hazardous to the safety of the occupants thereof, or which is so situated as to endanger other property as set forth in §32-1-1002(3)(c), C.R.S., whether or not a Notice has been previously issued.

c. An order signed by the Chief or his/her designee shall contain, as a minimum the following information;

1. Date of Issuance;
2. Name/Address of premises inspected;
3. Nature of violation or hazard;
4. Time limit for correction;
5. Right to Appeal, if any to the Board;
6. Right to appeal to the District Court and time limit;
7. Penalties for violation or order;
8. Signature of the Chief or his designee;
9. Acknowledgement of receipt signed by owner, lessee, agent, or other responsible person.

An appeal of Notice of Violation of Hazard may be made to the Board by delivery to the Chief in writing, a notice of appeal within five days of the issuance for the Notice of Violation Hazard. The appeal shall be heard at the next regular meeting or special meeting called for that purpose. The Board may affirm, rescind, or modify the Notice and may enter into such enforcement agreements as it deems proper.

4. An appeal of an Order of Immediate Correction of a Hazard may be made of a previously issued Notice of Violation or Hazard concerning the same violation or hazard. An appeal of an order must be in writing and filed with the Board within three days of issuance of the order.

5. The Board shall hear all such appeals and application for relief and render its decision thereon in accordance with its bylaws, rules and regulations.

6. In the event no appeal is made to the Board pursuant to this code and resolution or to the court pursuant to §32-1-1002(3), C.R.S., and compliance with the Order and/or correction of the hazard has not occurred, the Board may, upon recommendation by the Chief or upon its own motion, refer the matter to the District attorney of the county in which the violation occurs.
7. An appeal shall suspend the time limits for compliance or correction of a hazard or hazards, until the appeal is resolved for appeals of a Notice of Hazard which is issued pursuant to Section VIII, paragraph 3(a)(ii) herein. An appeal shall not suspend the time limit for compliance or correction of life safety deficiencies or violations. An appeal of an Order issued pursuant to Section VIII, paragraph 3(a)(ii) herein shall not suspend the time limits for compliance or correction, shall be made or rendered forthwith, unless the Order is suspended by the Board.

PENALTIES

Any owner, lessee, agent or occupant of any building or premises maintaining any condition likely to cause fire or to constitute an additional fire hazard or any condition which impedes or prevents the egress of persons from such buildings or premises in violation of provisions of §32-1-1002(3), C.R.S., shall be deemed to be maintaining a fire hazard. Any person who violates any provision of said subsection 3 is guilty of a misdemeanor and, upon conviction thereof, shall be punished by fine of not less than \$50.00 or no more than \$250.00. Each day in which such violation occurs shall constitute a separate violation of §32-1-1002(3), C.R.S.

1. The application of the above penalty shall not be construed to prevent the enforced removal or correction of prohibited conditions or other injunctive relief.

CHAPTER 3 GENERAL REQUIREMENTS

SECTION 301.2 PERMITS is repealed and reenacted to read:

301.2 Permit. Permits may be required as set forth in Section 105.6 for the activities or uses regulated by section 306, 307, 308, and 315.

SECTION 308 OPEN FLAMES, shall be amended with the insertion of:

308.1.6.3 Sky-Lanterns. A "Sky Lantern", also known as Kongming Lantern or Chinese Lantern, is a small hot air balloon made of paper, with an opening at the bottom where a small fire is suspended. The lighting of, and release of, Sky Lanterns shall be prohibited.

**CHAPTER 9
FIRE PROTECTION SYSTEMS**

Section 901.1 is repealed and reenacted to read:

901.1 Scope. The provisions of this chapter shall specify where fire protection and life safety systems are required and shall apply to the design, installation, inspection, operation, testing and maintenance of all fire protection systems. When the requirements of this code and the adopted building code are in conflict, the more restrictive apply.

**CHAPTER 56
EXPLOSIVES AND FIREWORKS**

Chapter 56, as it relates to Fireworks and Pyrotechnics Special Effects Materials, is deleted in its entirety and the applicable provisions of the Colorado State Statutes and Regulations, §12-28-101 shall govern all fireworks sales, storage and use.

Appendix C (Fire Hydrant Locations and Distribution) is adopted solely as a reference guide and shall not be utilized to preclude development in the unincorporated areas of the District which often lack sufficient water supplies and pressure to meet stated fire flow and hydrant spacing requirements.

VALIDITY AND CONFLICT

The District Board of Directors hereby declares that should any section, paragraph, sentence or word of the of this resolution of the code or standards hereby adopted be declared for any reason to be invalid, it is the intent of the Board of Directors that it would have passed all other portions of this resolution independent of elimination here from of any such portion as may be declared invalid. It is further declared by the Board of Directors that no provision of this resolution or the code or standards adopted herein be interpreted in conflict with existing State Law. In the event of a conflict between State Law and this code, State Law shall take precedent.

**APPENDIX O
ADDITIONAL CODE PROVISIONS**

Note: This appendix serves as a requirement for ISO as they require these provisions as part of their audit criteria.

BBQ AND CHARCOAL GRILL CODE

Chapter 3, Section 308.1.4 of the International Fire Code, entitled Open-Flame Cooking Devices, shall govern the use of BBQ and Charcoal grills within the District's boundaries. Pertinent provisions of the International Fire Code are summarized below and have been incorporated into this Resolution.

BBQ Grills

The use of propane grills, charcoal type grills, and other open flame cooking devices on combustible balconies and within 10 feet of combustible construction shall be prohibited.

Propane grills are regulated in the size of propane tank that is allowed. Only the small 2.5- lb. propane bottle sizes are allowed. Traditional BBQ grill propane tanks are a 20-lb. bottle, which in most cases is not allowed in multi-family dwellings.

These restrictions apply unless:

1. Your balcony/patio is made of concrete, steel or other non-combustible material
AND
2. The propane grill can be placed more than 10 feet away from combustible siding, decking, or other parts of the structure.

OR
3. The balcony/patio is protected by an automatic fire sprinkler system.

Charcoal Grills

Charcoal grills, Hibachis, and other open flame cooking appliances are not allowed.

These restrictions apply unless:

1. Your balcony/patio is made of concrete, steel or other non-combustible material
AND
2. The propane grill can be placed more than 10 feet away from combustible siding, decking, or other parts of the structure.

OR
3. The balcony/patio is protected by an automatic fire sprinkler system.

Exemption

It should be noted that one and two-family dwellings are exempt from these requirements.

FIRE LANE CODE

Chapter 5, Section 503 of the International Fire Code, entitled Fire Apparatus Access Roads, shall govern the use of fire lanes within the District's boundaries. Pertinent provisions of the International Fire Code are summarized below and have been incorporated into this Resolution.

The following shall apply within the District and shall define designated locations of signage, and marking of, and enforcement of, fire lanes within the authority and jurisdiction of the District in accordance with the International Fire Code and as approved by the Fire Code Official and / or local town ordinances where applicable.

Fire Lanes shall conform to the requirements of the International Fire Code, local town ordinances and shall be approved by the Fire Code Official and/or the Town of Berthoud prior to installation.

Fire Lanes shall be installed in accordance with the attached specifications.

Roadways, driveways and access ways shall not be marked as fire lanes without first obtaining approval from the District and/or the Town of Berthoud.

Signs and Markings

- a. All fire lanes and access roads must be marked with signs indicting "No Parking Fire Lane" as described in these specifications.
- b. Signs shall measure 12 X 18 inches and have red letters on white reflective background.
- c. Signs must be metal construction only. Plastic or wood signs are not acceptable.
- d. Signs shall be mounted at a minimum height of four feet to the maximum of seven feet.
- e. Signs shall be placed on both sides of the lane when striping is required on sides of the lane by the International Fire Code.
- f. Signs shall be placed along the fire lane at intervals not to exceed 50 feet and as designated by the fire code official.
- g. Outlining or painting the fire lane on the roadway surfaces shall be done in yellow, red, or white with contrasting letters that read "FIRE LANE" at 50' intervals and/or as specified in this document or otherwise directed by the Fire Code Official and Town of Berthoud.
- h. Existing fire lanes shall continue in effect as installed until such times as they are in need of re-striping due to wear or re-paving.

FIREWORKS CODE

Chapter 56, Section 5601.1.3 of the International Fire Code, entitled Fireworks, shall not govern the possession, manufacture, storage, sale, handling or use of fireworks within the District's boundaries. Instead, regulation of fireworks shall occur in accordance with the applicable provisions of Colorado state statutes and regulations, i.e., §12-28-101, et sec., CRS and any applicable municipal ordinance or county resolution/ordinance, shall govern all fireworks, their sale, storage, and use.

HAZARDOUS MATERIALS CODE

CHAPTER 50, Section 5001 of the International Fire Code, entitled Hazardous Materials, shall not govern the prevention, control and mitigation of dangerous conditions related to storage, dispensing, use and handling of hazardous materials within the District's boundaries. In addition regulation of hazardous materials shall occur in accordance with the following provisions.

Definitions

- a. **Hazardous Materials:** means those materials listed in Tables 1 and 2 of Title 49, Code of Federal Regulations, 172.04 (49 CFR 172.504), excluding highway route controlled quantities of radioactive materials as defined in 49 CFR 173.403 (1), excluding ores, and the wastes and tailing therefrom, and excluding special fireworks when the aggregate amount of flash powder does not exceed fifty pounds.

Intent

Applicable State and Federal Laws for the protection of public health, safety, and welfare arising from the transport of hazardous materials are capable of posing an unreasonable risk of health, safety, or property require compliance with Title 49 Code of Federal Regulations parts 101-173, 177 and 178; and Colorado Revised Statutes Title 42, Article 20 known as the Hazardous Materials Transportation Act of 1987 designate the Colorado State Patrol as the Authority Having Jurisdiction (AHJ) over hazardous materials on public roadways; and

Colorado Revised Statutes Title 42, Article 20, Section 103 defines a petitioning process for local government to create a new hazardous materials route or amend an existing route designation.

For purposes of protecting public health, the District hereby adopts the aforementioned Federal and State regulations as the standard by which commercial and private drivers will be measured for compliance with the transportation of hazardous materials within boundaries of the District.

Transport Routes

Motor vehicles carrying hazardous materials must be operated over the safest and most direct route to and from the organization and/or destination point. Such routes shall not pass through residential areas unless there is no practicable alternative. All vehicles shall comply with local truck routing and weight limitations and restrictions.

Exemption

This code shall not apply to farm machinery which is exempted from Colorado Revised Statute 42-3-102 or agricultural distribution equipment attached to or conveyed by farm machinery.

Reporting Incidents

Incidents involving hazardous materials are to be reported to the district by the transporter by telephone using 911 or any other effective means.

Transporters

Transporters of hazardous materials shall not permit or cause to be permitted the discharge of such materials into or upon any street, highway, sanitary sewer, drainage canal, ditch, storm drain, or ground, including private property except when such discharge is expressly permitted by the property owner and is otherwise prohibited.

Routes

The District hereby adopts the routes as established by the Colorado State Patrol, Hazardous Materials section as the recommended permissible means of transport for hazardous materials.

OPEN FLAME /OPEN BURNING CODE

Chapter 3, Section 307 of the International Fire Code, entitled Open Burning, Recreational Fires and Portable Outdoor Fire Places, the District shall govern open flames within the District's boundaries in accordance with the 2018 International Fire Code conditions set forth by the Department of Environmental Health and based on the authority of the Colorado Air Quality Act, 1979.

Definitions

1. Open Fires shall mean: any open burning, including camp and cooking fires; or welding, or operating an acetylene torch or other torch with open flame. Open Fires shall not include:
 - a. Fire in camp stoves or grills fueled by bottled gas or pressurized liquid as specifically

designed for cooking or heating purposes.

- b. Fires in permanently constructed stationary masonry or metal fireplaces specifically designed for the purpose of combustion.
- c. Fires in commercially operated wood and/or charcoal fired grills designed for cooking.

When smoking within an enclosed vehicle or building, butts and stubs must be disposed of within an approved trash receptacle or within the vehicle.

WEEDS, TALL GRASS, TRASH & GARBAGE CODE

Chapter 3, Sections 304.1.1 and 304.1.2 of the International Fire Code, entitled Waste Material and Vegetation, shall govern the regulation of combustible material within the District. Permanent provisions of the International Fire Code are summarized below and have been incorporated into this Resolution.

Weeds, tall grass, vegetation, vines and vegetation growth that is capable of being ignited and endangering property are prohibited. This is based on the adoption of the International Fire Code and the conditions below.

Definitions

a. Weeds: "weeds" shall include any non-grass type vegetation of which is in the opinion of the District over eight inches tall, other than that part of a vegetable, crop, flower garden, or landscaping that is regarded as a nuisance or potential light flashy fuel fire hazard. The International Wildland Urban Interface Code, 2018 Edition, Appendices A, B & D shall be used as a reference.

b. Grass: "grass" shall include any type of grass or weed, but not including crops grown as a source of income, including but not limited to corn, oats, barley and pasture land.

Date of Effect

This resolution shall take effect and be enforced within the incorporated municipalities and unincorporated portions of Boulder County from and after its approval as set forth in § 32-1-1002(1)(d), C.R.S.

[2018 International Fire Code Résolution Signature Page]

Adopted this 19th day of June, 2018

BERTHOUD FIRE PROTECTION DISTRICT

By Dan Hershman

Dan Hershman, President

ATTEST

By Gary Maggi

Gary Maggi, Secretary